

# **Fuel System Reliability - Pipeline Compressor Stations & Small Gas Turbines**

**Anthony J. Smalley**

**Southwest Research Institute**

**February 26, 2002**




# Themes

- **Gas-Fired Power Plants and Pipelines: A Tightly Linked Gas Energy System**
- **Electric Power Reliability and Availability require:**
  - **Power Plant Equipment Reliability, as well as...**
  - **Reliability of Pipeline Gas Delivery**
- **Both Power and Pipeline Industries use Gas Turbines**
- **Gas Turbine RAM and Condition Monitoring Technologies Benefit both Industries and Contribute to U.S. Energy Reliability**
- **Pipelines Need New Compression Concepts**

# **Some Observable Trends in the U.S. Gas Energy System**

- **Growth in Gas Consumption:**
  - **From 22 TCF Now to 30 by 2015 or Sooner and...to 35 by 2020?**
- **Majority of Growth for GT Power Plants**
- **Nuclear and Coal still 1<sup>st</sup> Dispatched, so:**
  - **GT Power Plant Load is Variable**


# Growth in Gas Consumption for Electric Power Projected Through 2015 (GRI)




# 500 MW GTCC Plant with Two GE Frame 7FAs



# 1998 Generation Capacity & Actual Generation (EIA)



# Typical & Representative Power Plant Flow Variation Over 3 Weeks




# **Fuel Gas Conditioning includes Filter / Separators / Heaters / Compression**






# Large GT Efficiency vs. Rotor Inlet Temperature (°F)


## *OEM & DOE-ATS R&D*



# Heat Rate vs. Compressor Discharge Pressure for Large CTs in Simple & Combined Cycle




# Compressor Discharge & Minimum Fuel Pressure (where known) for Large Combustion Turbines



# **Fuel Gas Lines to Turbines, Supplying Dry Gas, Whenever Needed, at CDP +200**




# Availability of Normalized Output of GT-Fleets - Power (from SPS-ORAP)




# Potential Consequences of Inadequate Compression

- **Result of Simulations by EVA, in “Pipelines to Power Lines Series” (sponsored by GRI/EPRI)...**

# Simulations show How Representative System Needs More Compression under Sustained High Demand



# Result with 7500 HP More Compression for Peaking





# Re-stated, Expanded Trends

- **Power System Gas Use Increasing**
- **GTCC Plants Need at Least Half Gas Growth**
- **GT Load Variable**
- **GT Power Market > 30X Mech. Drive Market**
- **Increasing CDP goes with Lower Heat Rate**
- **Turbine Inlet = CDP + 200 PSI**
- **Power Plant Load more Variable and Higher P**
- **Adequate Compression is Essential for Energy Reliability**


# **Pipeline Gas Compression Infrastructure - An Essential Element of Energy Reliability**

- **About 12 GW (16 Million HP)**
- **Turbines 25% by Population; 45% by Power**
- **Mostly Old, but will not be Replaced Soon**
- **Median Pipeline Turbine (~8,000 HP) Larger than Recips, but Smaller than Power Plant Turbines)**
- **Impacted by Emissions Regulations (NOx/HAPS)**
- **Burns ~3% of the Gas Delivered to End User**
- **Cost of Power Dominates True Operational Cost**


# **DOE Gas Infrastructure Program - Goals Relevant to Compression**

- **Increase Capacity 10% without Changing Infrastructure**
- **Improve Flexibility of System to Respond to Load Changes**
- **Decrease Air Emissions by 50% Per MMSCF by 2010**
- **Develop a Portfolio of Technologies to Reduce Costs:**
  - **Reduce Construction Costs >20% by 2005**
  - **Reduce O&M Costs 30% by 2005; 50% by 2010**


# Distribution of HP for Gas Turbines in Gas Transmission Service (approx.)



# Pipeline Compression Cost as a Function of Fuel Gas Cost (PRCI) *(based on 1994 records)*




# For One Company - Regression of Station Fuel Gas vs. Station HP-Hrs. - $R^2=96.7$ ; Slope=8.194 MCF/1000 HP-Hr. +/-0.15330



# Pipeline Gas Turbines

- **~1100 Gas Turbines in Pipeline Service**
- **Average Company Fleet >100 Units**
- **Small Units: Median Power = 6 MW (8,000 HP)**
- **Significant No. >100,000 Hrs.; Some >300,000**
- **Mostly 2-Shaft Variable Speed Mech. Drive**
- **Transition to Digital Controls still Ongoing**
- **GT Overhauls – Costliest Single Maintenance Item for Pipeline Operators**
- **Potential Condition Monitoring Concerns: Integrity; Performance; Hot Section Life**

# Estimated Overhaul Cost of Industrial Gas Turbines by Size (Based on Informal Estimates during Interviews; $\$ = \$34,452 + \$61.81 \text{ HP}$ )





# Pipeline Condition Monitoring Practice

- **Trending Periodic Data, e.g., Vibration and Temperature is increasingly Common, but**
- **Diagnostic/Prognostic Interpretation is Limited**
- **Performance Degradation Assessment Limited for Turbines and Centrifugal Compressors**
- **Life Management of Hot Section Components Essentially Non-Existent**


# **Pipeline Condition Monitoring Practice – *cont'd***

- **Digital Control Systems and MMI/HMIs provide New Opportunities**
- **GMRC, PRCI have Early Concept/Paper Studies**
- **DOE Recently Funded Programs for Large Power Generating Turbines have Potential for Beneficial Tech Transfer to Pipeline Application:**
  - **Coating Life Management**
  - **Prognostics and Diagnostics**


# **PRCI Program on “Engine/Compressor Performance Data Normalization (ECPDN)” Objective:**

- **To Enable Intelligent Interpretation of Compressor Station Digital Data, with:**
  - **Expected Values or Normalized Values based on Changing Conditions,**
  - **Alarms based on Significant Deviation from Expected Values, and**
  - **Operator Action Guidance.**
- **Turbine Parameters include: CDP; Gas Compressor Head and Efficiency; Filter Pressure Drop**

# Fleet Monitoring Concept: Local Functional Architecture (GMRC)




# Fleet Monitoring Concept: Remote System Functional Architecture (GMRC)




# **Anticipated New Compression: ~4.1 GW (5.5 Million HP) by 2015**

- **Engine Driven Recips**
- **Motor Driven Recips**
- **Gas Turbine Driven Centrifugals**
- **Motor Driven Centrifugals**

# Pipeline Gas Turbine Driver



# Pipeline Motor-Driven Centrifugal + Gearbox Speed Increaser







# Engine Driven Reciprocating Compressor Installation




# Motor Driven Reciprocating Compressor Installation




# Advanced Pipeline Compression Concept: The In-line Electric Motor Driven Compressor “IEMDC”




# IEMDC: Pipeline Efficiency Gain Via Illustrative 16.7% Increased Line-Pack



# IEMDC Details of Construction



# Advanced Compression Concept: Sanderson Variable Stroke Concept



# Summary

- **Electric Power Reliability and Availability Need Adequate, Flexible, Reliable Pipeline Compression**
- **Gas Turbine RAM and Condition Monitoring Technologies Benefit both Industries and Contribute to U.S. Energy Reliability**
- **Pipelines Need New Compression Concepts**
- **DOE has an Important Role to Play**